



Results Report

Order ID: 9052290

Miller & Sons Water Conditioning
2021 Horseshoe Road
Lancaster, PA 17602

Project: Conestoga Elementary School

Attn: Brandy Zaia

Regulatory ID: 7361063

Sample Number: 9052290-01

Site: 401 (Rm. A114)

Sample ID:

Collector: KF

Collect Date: 05/06/2019 12:25 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/16/19 RPV 05/17/19 8:53 MAW

Sample Number: 9052290-02

Site: 402 (Rm. A107 Nurse Handwash Sink)

Sample ID:

Collector: KF

Collect Date: 05/06/2019 12:30 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/16/19 RPV 05/17/19 8:55 MAW

Sample Number: 9052290-03

Site: 403 (Rm. A119 Academic Common Han

Sample ID:

Collector: KF

Collect Date: 05/06/2019 12:35 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/16/19 RPV 05/17/19 8:57 MAW

Sample Number: 9052290-04

Site: 404 (Rm. C103 Faculty Handwash Sink)

Sample ID:

Collector: KF

Collect Date: 05/06/2019 12:40 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/16/19 RPV 05/17/19 9:03 MAW

Sample Number: 9052290-05

Site: 405 (Rm A133 Media Center Handwash

Sample ID:

Collector: KF

Collect Date: 05/06/2019 12:45 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/16/19 RPV 05/17/19 9:05 MAW

Report Generated On: 05/17/2019 2:34 pm

9052290

STL_Results Revision #1.6

Effective: 07/09/2014



SUBURBAN TESTING LABS

Sample Number: 9052290-06	Site: 406 (Kitchen Dishroom Handwash Sink)	Sample ID:
Collector: KF	Collect Date: 05/06/2019 12:50 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/16/19	RPV	05/17/19 9:07	MAW
------	---------	------	-----------	-------	---	----------	-----	---------------	-----

Sample Number: 9052290-07	Site: 407 (Kitchen 3 - Bay Sink)	Sample ID:
Collector: KF	Collect Date: 05/06/2019 12:55 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/16/19	RPV	05/17/19 9:09	MAW
------	---------	------	-----------	-------	---	----------	-----	---------------	-----

Sample Number: 9052290-08	Site: 408 (Kitchen Handwash by Freezer)	Sample ID:
Collector: KF	Collect Date: 05/06/2019 1:00 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/15/19	MAW	05/15/19 19:46	MAW
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9052290-09	Site: 409 (Kitchen 2- Baysink by Ice Machine)	Sample ID:
Collector: KF	Collect Date: 05/06/2019 1:05 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/15/19	MAW	05/15/19 19:48	MAW
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9052290-10	Site: 410 (Kitchen Handwash between Refrige	Sample ID:
Collector: KF	Collect Date: 05/06/2019 1:10 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/15/19	MAW	05/15/19 19:50	MAW
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 05/17/2019 2:34 pm 9052290
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Kelly Mays
Project Manager II

Report Generated On: 05/17/2019 2:34 pm 9052290
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS



9052290
Kelly Mays

(1 of 2)

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Miller & Sons, Inc.
Address: _____ Phone: _____

Fax: _____
Contact Name: Brandy Zaid Email: _____
Comments: _____

Project Name: Conestoga Elementary
Address: 100 Hill Street
Conestoga, PA 17516
Payment / P.O. Info: _____

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
401	(Rm. A114)	5/6/19	1225	KF	lead	1	PW	G	P		
402	(Rm A107 Nurse hand wash sink)		1230	I	lead	1	PW	G	P		
403	(Rm. A119 Academic Common hand wash sink)		1235	I	lead	1	PW	G	P		
404	(Rm. C103 Faculty hand wash sink)		1240	I	lead	1	PW	G	P		
405	(Rm. A133 Media Center hand wash sink)		1245	I	lead	1	PW	G	P		
406	(Kitchen dish room, hand wash sink)		1250	I	lead	1	PW	G	P		
407	(Kitchen 3-Bay sink)		1255	I	lead	1	PW	G	P		
408	(Kitchen hand wash by freezer)		1300	I	lead	1	PW	G	P		


continued...

Relinquished By: <u>[Signature]</u>	Date: <u>5/6/19</u>	Temp °C: <u>3.8</u> Acceptable: <u>Y/N</u>	Sample Conditions Submitted with COC? <u>Y/N</u> Number of containers match number on COC? <u>Y/N</u> All containers in tact? <u>Y/N</u> Tests within holding times <u>Y/N</u> 40 mL VOA vials free of headspace? <u>Y/N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options [] SDWA Reporting PWSID: _____ [] Fax [] Email [] Other _____ [] Return a copy of this form with Report
	Time: <u>1600</u>					
Received By: <u>[Signature]</u>	Date: <u>5-7-19</u>	Temp °C: <u>3.8</u> Acceptable: <u>Y/N</u>				
Relinquished By: <u>[Signature]</u>	Time: <u>08:30</u>					
Received in Lab By: <u>[Signature]</u>	Date: <u>5-7-19</u>	Temp °C: <u>3.8</u> Acceptable: <u>Y/N</u>				
<u>CS 8</u>	Time: <u>1110</u>					

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.3 Effective May 16, 2013.
Shaded areas are for STL use only.



SUBURBAN TESTING LABS



9052290
Kelly Mays

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

com

Order ID: _____

Client Name: Miller & Sins, Inc.

Address: _____ Phone: _____

_____ Fax: _____

Contact Name: Brandy Laia Email: _____

Comments:

Project Name: Conestoga Elementary

Address: 100 Hill Street

Conestoga, PA 17516

Payment / P.O. Info: _____

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	409 (Kitchen 2-Bay sink by ice machine)	5/6/19	1305	KF	lead	1	PW	G	P		
	410 (Kitchen between hand wash between refrigerator and ice machine)	5/6/19	1310	L	lead	1	PW	G	P		
		5/6/19									

Relinquished By: <u>Kyle F...</u>	Date: <u>5/6/19</u> Time: <u>1400</u>		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By: <u>[Signature]</u>	Date: <u>5-2-19</u> Time: <u>08:30</u>	Temp °C: <u>3.8</u> Acceptable: <u>Y</u> N	Submitted with COC? <u>Y</u> / N	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	P = Plastic G = Glass O = Other	[] SDWA Reporting PWSID: _____
Relinquished By: <u>[Signature]</u>	Date: <u>5-2-19</u> Time: <u>11:10</u>	Temp °C: <u>5.8</u> Acceptable: <u>Y</u> / N	Number of containers match number on COC? <u>Y</u> / N	PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Preservative Key	[] Fax [] Email [] Other _____
Received in Lab By: <u>CS 2</u>	Date: <u>5-7-19</u> Time: <u>11:10</u>	Temp °C: <u>3.80</u> Acceptable: <u>Y</u> / N	All containers in tact? <u>Y</u> / N	Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	[] Return a copy of this form with Report
			Tests within holding times <u>Y</u> / N	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence		
			40 mL VOA vials free of headspace? <u>Y</u> / N			

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.3 Effective May 16, 2013.
Shaded areas are for STL use only.