



Results Report

Order ID: 9053798

Miller & Sons Water Conditioning
2021 Horseshoe Road
Lancaster, PA 17602

Project: Eshleman Elementary

Attn: Brandy Zaia

Regulatory ID: 7360568

Sample Number: 9053798-01

Site: 401 (Office Hand Wash)

Sample ID:

Collector: KF

Collect Date: 05/16/2019 10:10 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/28/19	MAW	05/28/19 16:39	RJS
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9053798-02

Site: 402 (Nurses Room)

Sample ID:

Collector: KF

Collect Date: 05/16/2019 10:15 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/28/19	MAW	05/28/19 16:21	RJS
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9053798-03

Site: 403 (Nurses Exam Room)

Sample ID:

Collector: KF

Collect Date: 05/16/2019 10:20 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/28/19	MAW	05/28/19 16:23	RJS
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9053798-04

Site: 404 (Custodial by Instrument)

Sample ID:

Collector: KF

Collect Date: 05/16/2019 10:30 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/28/19	MAW	05/28/19 16:25	RJS
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9053798-05

Site: 405 (Electrical Room Slop Sink)

Sample ID:

Collector: KF

Collect Date: 05/16/2019 10:35 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/28/19	MAW	05/28/19 16:27	RJS
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Report Generated On: 05/29/2019 3:34 pm
STL_Results Revision #1.69053798
Effective: 07/09/2014



SUBURBAN TESTING LABS

Sample Number: 9053798-06	Site: 406 (Faculty Lunch Room)	Sample ID:
Collector: KF	Collect Date: 05/16/2019 10:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	0.005	mg/L	EPA 200.8	0.001	1	05/28/19	MAW	05/28/19 16:33	RJS
------	-------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9053798-07	Site: 407 (Kitchen 3 Bay)	Sample ID:
Collector: KF	Collect Date: 05/16/2019 10:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/28/19	MAW	05/28/19 16:35	RJS
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9053798-08	Site: 408 (Kitchen 2 Bay)	Sample ID:
Collector: KF	Collect Date: 05/16/2019 10:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/28/19	MAW	05/28/19 16:14	RJS
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9053798-09	Site: 409 (Kitchen Restroom)	Sample ID:
Collector: KF	Collect Date: 05/16/2019 10:55 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/28/19	MAW	05/28/19 16:37	RJS
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 9053798-10	Site: 410 (Room 18 Classroom)	Sample ID:
Collector: KF	Collect Date: 05/16/2019 11:05 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.001	1	05/28/19	MAW	05/28/19 16:43	RJS
------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 05/29/2019 3:34 pm
STL_Results Revision #1.6

9053798
Effective: 07/09/2014



SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Kelly Mays
Project Manager II

Report Generated On: 05/29/2019 3:34 pm 9053798
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS



9053798
Kelly Mays

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Page 1 of 2

Order ID: _____

Client Name: Miller & Sons Inc
Address: 2021 Horseshoe Rd
Concastor, PA 17002
Contact Name: Brandy Zaia
Phone: (717) 397-4609
Fax: (717) 397-4649
Email: Bzaia@Mikersolt.com

Project Name: Eshleman Elementary
Address: 545 Leaman Ave
Milleville, PA 17551
Payment / P.O. Info: _____

Comments:

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below					Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative		
	401 (Office Hand wash)	5/16/19	1010	KF	lead	1	Pw	G	P			
	402 (Nurses Room) ✓	I	1015	I	lead	1	Pw	G	P			
	403 (Nurses Exam Room) ✓		1020		lead	1	Pw	G	P			
	404 (Custodial by instrument) ✓		1030		lead	1	Pw	G	P			
	405 (Electrical Room scope) ✓		1035		lead	1	Pw	G	P			
	406 (Faculty lunch Room) ✓		1040		lead	1	Pw	G	P			
	407 (Kitchen 3 Bay) ✓		1045		lead	1	Pw	G	P			
	408 (Kitchen 2 Bay) ✓		1050		lead	1	Pw	G	P			

Relinquished By: <u>Kyle Fagan</u>	Date: <u>5/16/19</u>		Sample Conditions		Matrix Key		Bottle Type Key		Reporting Options		
Received By: <u>[Signature]</u>	Time: <u>1530</u>		Submitted with COC? <input checked="" type="checkbox"/> Y / N	NPW = Non-Potable Water	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)		P = Plastic	[] SDWA Reporting			
Relinquished By: <u>[Signature]</u>	Date: <u>5-16-19</u>	Temp °C: <u>14</u>	Number of containers match number on COC? <input type="checkbox"/> Y / N	PW = Potable Water (not for SDWA compliance)	SDWA = Safe Drinking Water Act Potable Sample		G = Glass	PWSID: _____			
Received in Lab By: <u>EW 8</u>	Time: <u>1715</u>	Acceptable: Y / N	All containers in tact? <input checked="" type="checkbox"/> Y / N	Sample Type Key		SDWA Sample Types	O = Other	[] Fax			
	Date: <u>5-16-19</u>	Temp °C: <u>2.5</u>	Tests within holding times <input type="checkbox"/> Y / N	G = Grab	D = Distribution	N = Sodium Thiosulfate	[] Email				
	Time: <u>1812</u>	Acceptable: Y / N	40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y / N	E = Entry Point	R = Raw	A = Ascorbic Acid	[] Other _____				
	Date: <u>5-16-19</u>	Temp °C: <u>2.5</u>		C = Check	S = Special	H = HNO ₃	[] Return a copy of this form with Report				
	Time: <u>1812</u>	Acceptable: Y / N		M = Maximum Residence	24HC = 24 Hr. Composite	OH = NaOH					
						O = Other					
						NA = None Required					

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.3 Effective May 16, 2013.
Shaded areas are for STL use only.



9053798
Kelly Mays

2

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

:om

Page 2 of 2

Order ID:

Client Name: Miller & Sons Inc
Address: 2021 Horseshoe Rd
Lancaster PA 17602
Contact Name: Brandy Zava

Comments:

Project Name: Eshleman Elementary
Address: 845 Leaman Ave.
Millersville, PA 17551
Payment / P.O. Info: _____

Payment / P.O. Info:

[illegible]

Relinquished By:	Date:	Temp °C:	Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
<i>Kyle Fugate</i>	<i>5/10/19</i>					
Received By:	Date:	Temp °C:	Number of containers match number on COC?	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	P = Plastic G = Glass O = Other	[] SDWA Reporting PWSID: _____
<i>Wiley A</i>	<i>5-16-19</i>					
Relinquished By:	Date:	Temp °C:	All containers in tact?	PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Preservative Key	[] Fax [] Email [] Other
<i>Malen</i>	<i>5-16-19</i>					
Received In Lab By:	Date:	Temp °C:	Tests within holding times	SDWA = Safe Drinking Water Act Potable Sample	N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	[] Return a copy of this form with Report
<i>EW 2</i>	<i>5-16-19</i>					
	Date:	Temp °C:	40 mL VOA vials free of headspace?	Sample Type Key	SDWA Sample Types	
	<i>1812</i>					

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.3 Effective May 16, 2013.
Shaded areas are for STL use only.