



## Results Report

Order ID: 9052292

Miller & Sons Water Conditioning  
2021 Horseshoe Road  
Lancaster, PA 17602

Project: Martic Elementary School

Attn: Brandy Zaia

Regulatory ID: 7360568

Sample Number: 9052292-01

Site: 401 (Nurses Office Sink A136)

Sample ID:

Collector: KF

Collect Date: 05/06/2019 2:35 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/15/19 MAW 05/15/19 19:52 MAW

Sample Number: 9052292-02

Site: 402 (Nurses Office Exam Room Sink A1)

Sample ID:

Collector: KF

Collect Date: 05/06/2019 2:40 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/15/19 MAW 05/15/19 19:22 MAW

Sample Number: 9052292-03

Site: 403 (Nurses Restroom)

Sample ID:

Collector: KF

Collect Date: 05/06/2019 2:45 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/15/19 MAW 05/15/19 19:54 MAW

Sample Number: 9052292-04

Site: 404 (Faculty Lounge Sink)

Sample ID:

Collector: KF

Collect Date: 05/06/2019 2:50 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/15/19 MAW 05/15/19 18:41 MAW

Sample Number: 9052292-05

Site: 405 (Faculty Restroom #1)

Sample ID:

Collector: KF

Collect Date: 05/06/2019 2:55 pm

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/15/19 MAW 05/15/19 19:56 MAW

Report Generated On: 05/16/2019 4:20 pm

9052292

STL\_Results Revision #1.6

Effective: 07/09/2014



# SUBURBAN TESTING LABS

Sample Number: 9052292-06	Site: 406 (Faculty Restroom #2)	Sample ID:
Collector: KF	Collect Date: 05/06/2019 3:00 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

## Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/15/19 MAW 05/15/19 19:58 MAW

Sample Number: 9052292-07	Site: 407 (A133 Custodial Sink)	Sample ID:
Collector: KF	Collect Date: 05/06/2019 3:05 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

## Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/15/19 MAW 05/15/19 20:00 MAW

Sample Number: 9052292-08	Site: 408 (DIII Faculty Restroom)	Sample ID:
Collector: KF	Collect Date: 05/06/2019 3:10 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

## Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/15/19 MAW 05/15/19 20:02 MAW

Sample Number: 9052292-09	Site: 409 (Kitchen Restroom)	Sample ID:
Collector: KF	Collect Date: 05/06/2019 3:15 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

## Metals

Lead 0.001 mg/L EPA 200.8 0.001 1 05/15/19 MAW 05/15/19 20:04 MAW

Sample Number: 9052292-10	Site: 410 (Kitchen 2- Bay Sink)	Sample ID:
Collector: KF	Collect Date: 05/06/2019 3:20 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

## Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/15/19 MAW 05/15/19 19:26 MAW

## Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 05/16/2019 4:20 pm 9052292  
STL\_Results Revision #1.6 Effective: 07/09/2014





# SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Kelly Mays  
Project Manager II

Report Generated On: 05/16/2019 4:20 pm 9052292  
STL\_Results Revision #1.6 Effective: 07/09/2014





9052292  
Kelly Mays

1 of 2  
TAT (Circle One): Standard 24hr / 48hr / 72hr / Other \_\_\_\_\_  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

Client Name: Miller & Sons, Inc.

Address: \_\_\_\_\_

Phone: \_\_\_\_\_

Fax: \_\_\_\_\_

Contact Name: Brandy Zaic

Email: \_\_\_\_\_

Comments: \_\_\_\_\_

Project Name: Martie Elementary

Address: 266 Martie Heights Dr.

Holtwood, PA 17532

Payment / P.O. Info: \_\_\_\_\_

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
401	Nurses office sink A136)	5/6/19	1435	KF	Lead	1	PW	G	P		
402	Nurses office exam room sink A135)		1440		Lead	1	PW	G	P		
403	Nurse restroom)		1445		Lead	1	PW	G	P		
404	Faculty lounge sink)		1450		Lead	1	PW	G	P		
405	Faculty restroom #1)		1455		Lead	1	PW	G	P		
406	Faculty restroom #2)		1500		Lead	1	PW	G	P		
407	A133 Custodial sink)		1505		Lead	1	PW	G	P		
408	D111 Faculty restroom)		1510		Lead	1	PW	G	P		

continued..

Relinquished By: <u>[Signature]</u>	Date: <u>5/6/19</u>		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By: <u>[Signature]</u>	Time: <u>1600</u>		Submitted with COC? <u>(Y/N)</u>	NPW = Non-Potable Water	P = Plastic	[ ] SDWA Reporting
Relinquished By: <u>[Signature]</u>	Date: <u>5-7-19</u>	Temp °C: <u>3.8°C</u>	Number of containers match number on COC? <u>(Y/N)</u>	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	G = Glass	PWSID: _____
Received in Lab By: <u>[Signature]</u>	Time: <u>6:17</u>	Acceptable: <u>Y/N</u>	All containers in tact? <u>(Y/N)</u>	PW = Potable Water (not for SDWA compliance)	O = Other	[ ] Fax
	Date: <u>5-7-19</u>	Temp °C: <u>3.8</u>	Tests within holding times <u>(Y/N)</u>	SDWA = Safe Drinking Water Act Potable Sample	Preservative Key	[ ] Email
	Time: <u>11:10</u>	Acceptable: <u>Y/N</u>	40 mL VOA vials free of headspace? <u>Y/N</u>	Sample Type Key	N = Sodium Thiosulfate	[ ] Other _____
	Date: <u>5-7-19</u>	Temp °C: <u>3.8</u>		SDWA Sample Types	A = Ascorbic Acid	[ ] Return a copy of this form with Report
	Time: <u>1110</u>	Acceptable: <u>Y/N</u>		G = Grab	H = HNO <sub>3</sub>	
				8HC = 8 Hr. Composite	C = HCl	
				24HC = 24 Hr. Composite	S = H <sub>2</sub> SO <sub>4</sub>	
					OH = NaOH	
					O = Other	
					NA = None Required	

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.3 Effective May 16, 2013.  
Shaded areas are for STL use only.



# SUBURBAN TESTING LABS



9052292  
Kelly Mays

(2 of 2)  
TAT (Circle One): Standard 24hr / 48hr / 72hr / Other \_\_\_\_\_  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

Client Name: Miller & Sons, Inc.  
Address: \_\_\_\_\_ Phone: \_\_\_\_\_  
\_\_\_\_\_  
Fax: \_\_\_\_\_  
Contact Name: \_\_\_\_\_ Email: \_\_\_\_\_  
Comments: \_\_\_\_\_

Project Name: Martie Elementary  
Address: 266 Martie Heights Drive  
Holtwood, PA 17532  
Payment / P.O. Info: \_\_\_\_\_

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	40a (Kitchen restroom)	5/6/19	1515	KF	Lead	1	PW	G	P		
	410 (Kitchen 2-Bay sink)	L	1520	L	Lead	1	PW	G	P		

Relinquished By: 	Date: <u>5/6/19</u>	Temp °C: <u>3.80</u> Acceptable: <u>Y/N</u>	Sample Conditions Submitted with COC? <u>Y/N</u> Number of containers match number on COC? <u>Y/N</u> All containers in tact? <u>Y/N</u> Tests within holding times <u>Y/N</u> 40 mL VOA vials free of headspace? <u>Y/N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options [ ] SDWA Reporting PWSID: _____ [ ] Fax [ ] Email [ ] Other _____ [ ] Return a copy of this form with Report
	Time: <u>1600</u>					
Received By: 	Date: <u>5-7-19</u>	Temp °C: <u>3.80</u> Acceptable: <u>Y/N</u>	Sample Conditions Submitted with COC? <u>Y/N</u> Number of containers match number on COC? <u>Y/N</u> All containers in tact? <u>Y/N</u> Tests within holding times <u>Y/N</u> 40 mL VOA vials free of headspace? <u>Y/N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options [ ] SDWA Reporting PWSID: _____ [ ] Fax [ ] Email [ ] Other _____ [ ] Return a copy of this form with Report
Relinquished By: 	Date: <u>5-7-19</u>					
Received in Lab By: <u>CJ 2</u>	Date: <u>5-7-19</u>	Temp °C: <u>3.80</u> Acceptable: <u>Y/N</u>	Sample Conditions Submitted with COC? <u>Y/N</u> Number of containers match number on COC? <u>Y/N</u> All containers in tact? <u>Y/N</u> Tests within holding times <u>Y/N</u> 40 mL VOA vials free of headspace? <u>Y/N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options [ ] SDWA Reporting PWSID: _____ [ ] Fax [ ] Email [ ] Other _____ [ ] Return a copy of this form with Report
	Time: <u>1110</u>					

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.3 Effective May 16, 2013.  
Shaded areas are for STL use only.