



Results Report

Order ID: 9052539

Miller & Sons Water Conditioning
2021 Horseshoe Road
Lancaster, PA 17602

Project: Pequea Elementary
802 Millwood Road
Willow Street, PA 17584

Attn: Brandy Zaia

Regulatory ID:

Sample Number: 9052539-01		Site: 401 Faculty Lunch		Sample ID:						
Collector: KF		Collect Date: 05/07/2019 8:35 am		Sample Type: Grab						
Department / Test / Parameter		Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/16/19 RPV 05/17/19 9:52 MAW

Sample Number: 9052539-02		Site: 402 Nurses Room		Sample ID:						
Collector: KF		Collect Date: 05/07/2019 8:10 am		Sample Type: Grab						
Department / Test / Parameter		Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/16/19 RPV 05/17/19 9:54 MAW

Sample Number: 9052539-03		Site: 403 A109 Nurses Exam		Sample ID:						
Collector: KF		Collect Date: 05/07/2019 8:15 am		Sample Type: Grab						
Department / Test / Parameter		Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/16/19 RPV 05/17/19 9:56 MAW

Sample Number: 9052539-04		Site: 404 Office Restroom		Sample ID:						
Collector: KF		Collect Date: 05/07/2019 8:20 am		Sample Type: Grab						
Department / Test / Parameter		Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/16/19 RPV 05/17/19 9:58 MAW

Sample Number: 9052539-05		Site: 405 A115 Work Room Office		Sample ID:						
Collector: KF		Collect Date: 05/07/2019 8:25 am		Sample Type: Grab						
Department / Test / Parameter		Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/16/19 RPV 05/17/19 10:00 MAW

Report Generated On: 05/20/2019 5:11 pm
STL_Results Revision #1.6

9052539
Effective: 07/09/2014



SUBURBAN TESTING LABS

Sample Number: 9052539-06
Collector: KF

Site: 406 Restroom by Gym
Collect Date: 05/07/2019 8:40 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/16/19 RPV 05/17/19 10:02 MAW

Sample Number: 9052539-07
Collector: KF

Site: 407 Restroom Main Lobby
Collect Date: 05/07/2019 8:45 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/16/19 RPV 05/17/19 10:04 MAW

Sample Number: 9052539-08
Collector: KF

Site: 408 B131 Kitchen by Cashier
Collect Date: 05/07/2019 8:50 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/16/19 RPV 05/17/19 10:06 MAW

Sample Number: 9052539-09
Collector: KF

Site: 409 Kitchen 2 Bay
Collect Date: 05/07/2019 8:55 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/17/19 MAW 05/17/19 18:28 RPV

Sample Number: 9052539-10
Collector: KF

Site: 410 Kitchen Dish Room
Collect Date: 05/07/2019 9:00 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.001 1 05/17/19 MAW 05/17/19 18:30 RPV

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 05/20/2019 5:11 pm 9052539
STL_Results Revision #1.6 Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595 Fax: 610-375-4090 suburbantestinglabs.com

SUBURBAN TESTING LABS



PADEP 06-00208



SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Kelly Mays
Project Manager II

Report Generated On: 05/20/2019 5:11 pm 9052539
STL_Results Revision #1.6 Effective: 07/09/2014





9052539
Kelly Mays

10F2

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

abs.com

Order ID: _____

Client Name: Miller + Sons Inc

Address: _____ Phone: _____

Fax: _____

Contact Name: Brandy Zaira Email: _____

Comments:

* p. w 15 drops.

Project Name: Pequea Elementary

Address: 802 Millwood Road
Wilkes Street, PA 17584

Payment / P.O. Info: _____


STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
(1) - 250 mL P-bottle											
* 401 Faculty Lunch		5/7/19	0835	KG	lead	1	PW	G	P		
* 402 Nurses Room			0810		lead	1	PW	G	P		
* 403 A109 Nurses Exam			0815		lead	1	PW	G	P		
* 404 Office Restroom			0820		lead	1	PW	G	P		
* 405 A115 Work Room			0825		lead	1	PW	G	P		
* 406 Restroom by Gym			0840		lead	1	PW	G	P		
* 407 Restroom Main lobby			0845		lead	1	PW	G	P		
* 408 B131 Kitchen by			0850		lead	1	PW	G	P		

Relinquished By: <u>[Signature]</u>	Date: <u>5/7/19</u>		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By: <u>[Signature]</u>	Time: <u>1700</u>		Submitted with COC? <u>Y/N</u>	NPW = Non-Potable Water	P = Plastic	[] SDWA Reporting
	Date: <u>5-8-19</u>	Temp °C: <u>29°C</u>	Number of containers match number on COC? <u>Y/N</u>	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	G = Glass	PWSID: _____
	Time: <u>08:45</u>	Acceptable: <u>Y/N</u>	All containers in tact? <u>Y/N</u>	PW = Potable Water (not for SDWA compliance)	O = Other	[] Fax
Relinquished By: <u>[Signature]</u>	Date: <u>5-8-19</u>	Temp °C: <u>38°C</u>	Tests within holding times? <u>Y/N</u>	SDWA = Safe Drinking Water Act Potable Sample	Preservative Key	[] Email
Received in Lab By: <u>[Signature]</u>	Time: <u>12:00</u>	Acceptable: <u>Y/N</u>	40 mL VOA vials free of headspace? <u>Y/N</u>	Sample Type Key	N = Sodium Thiosulfate	[] Other
	Date: <u>5/8/19</u>	Temp °C: _____		8HC = 8 Hr. Composite	A = Ascorbic Acid	[] Return a copy of this form with Report
	Time: <u>1200</u>	Acceptable: <u>Y/N</u>		24HC = 24 Hr. Composite	H = HNO ₃	
					C = HCl	
					R = Raw	
					C = Check	
					S = Special	
					M = Maximum	
					Residence	
					NA = None	
					Required	

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.3 Effective May 16, 2013.
Shaded areas are for STL use only.



SUBURBAN
TESTING LABS



9052539
Kelly Mays

2 of 2

TAT (Circle One): Standard 24hr / 48hr / 72hr / Other____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

.com

Order ID:

Client Name: Miller & Sons Inc

Address: _____

Phone: _____

Fax: _____

Contact Name: Brandt Zaver

Email: _____

Comments:

* P w/ 15 drops

[illegible]

Relinquished By:	Date:	Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
<i>Kyle Fager</i>	5/7/19	Submitted with COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	NPW = Non-Potable Water	P = Plastic	<input type="checkbox"/> SDWA Reporting
	Time: 1700		Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	G = Glass	PWSID: _____
Received By:	Date:	Number of containers match number on COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	PW = Potable Water (not for SDWA compliance)	O = Other	<input type="checkbox"/> Fax
<i>[Signature]</i>	5-8-19		SDWA = Safe Drinking Water Act Potable Sample	Preservative Key	<input type="checkbox"/> Email
	Time: 08:45	Acceptable: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N		N = Sodium	<input type="checkbox"/> Other _____
Relinquished By:	Date:	All containers in tact? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Sample Type Key	A = Ascorbic Acid	
<i>[Signature]</i>	5-8-19		G = Grab	H = HNO ₃	<input type="checkbox"/> Return a copy of this form with Report
	Time: 12:00	Tests within holding times <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	8HC = 8 Hr. Composite	C = HCl	
Received In Lab By:	Date:	40 mL VOA vials free of headspace? <input type="checkbox"/> Y <input type="checkbox"/> N	24HC = 24 Hr. Composite	S = H ₂ SO ₄	
<i>[Signature]</i>	5/8/19			OH = NaOH	
	Time: 1700	Acceptable: <input type="checkbox"/> Y <input type="checkbox"/> N		O = Other	
				NA = None Required	

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.3 Effective May 16, 2013.
Shaded areas are for STL use only.